

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. DWTL-FZR/032/2025-26.

Date : 18/01/2025

It is certified that an inspection team headed by Harpreet Singh
Lab Chemist, Distt Water Testing Laboratory, Ferozepur (Name of Officers
with designation) from Water Supply & Sanitation Deptt, FZR (Name of
Department/Office) inspected the Punjab public school,
Nathe Shah wala, Block & Distt. Ferozepur (Name & Address of
the School) on 17-01-2025 and found that the Punjab public
School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of one year i.e.

18/01/2025 to 17/01/2026.

Signature with Seal:

Name

Designation

Harpreet Singh
18/01/2025
Lab Chemist/J.E. Incharge
Distt. Water Testing Laboratory
W/s & Sanitation Deptt.
Ferozepur
Lab Chemist

To

The principal
Punjab public school,
Nathe Shah wala, Block & Distt. Ferozepur

(Name & Address of the Institution)



**WATER SUPPLY & SANITATION DISTRICT LEVEL WATER TESTING
LABORATORY
ANALYSIS REPORT OF WATER SAMPLES**

Particulars of Samples

	Sample No.1	Sample No . 2	<u>Date of Receipt</u>	<u>Date of Conducting</u>
			17/01/25....	18/01/25....
1 Place/Name of Village	Punjab public school, Nathe shah wala.			
2 Block/District	Ferozepur/ Ferozepur			
3 Source	R.O.			
4 Date and time of collection	17-01-2025			
5 Depth	7			
6 Spring Level	-			
7 Name and designation of the Person collecting the sample	S. Kuldeep Singh (Principal)			

TEST RESULTS

PHYSICAL AND CHEMICAL

1 Turbidity (JTU)	7			
2 Colour (Units on Pt-Co Scale)	-			
3 Taste and odors (Qualitative)	-			
4 PH	6.8			
5 Total Dissolved Solids mg/l	056			
6 Total Alkalinity (as CaCo3) mg/l	32			
7 Hardness (as CaCo3)mg/l				
(a) Total	24			
(b) Calcium	06			
(c) Magnesium	-			
(d) Carbonate	-			
(e) Non-Carbonate	-			

